

**City of Port Angeles Schedule A
Invitation for Bid**

WTP SCADA GENERATOR PURCHASE
Purchase Contract: MEC-2024-41

GENERAL DESCRIPTION: Commercial/Industrial 20 KW Cummings Diesel Generator with fuel tank, 200-amp Automatic Transfer Switch (ATS), and single phase 3KVA 240v to 208v transformer.

DELIVERY LOCATION: 3501 W 18th St. Bldg J, Port Angeles WA, 98363

DELIVERY HOURS: Delivery shall be Monday through Friday, excluding weekends and all legal holidays, between the hours of 8:00 AM and 2:30 PM. The following individuals **must** be notified 24 hours prior to delivery:

Benjie Flores at 360-417-4860 or Bflores@cityofpa.us
Rob Feller at 360-460-5316 or rfeller@cityofpa.us

SPECIFICATIONS:

Product / Description	Specifications
<p>Cummins 20KW Diesel Generator With Undermount Tank Model C20 D6 Commercial/Industrial -120/240v AC Single Phase -6 Amp Battery Charger -12 Volt Starting Voltage -24 Hour Tank Capacity -pcc1.1 two-wire start control -100 amp circuit breaker -coolant heater -68.4 dba enclosure -self contained engine mounted muffler -Double Wall Diesel Tank with Leak Detection</p>	<p>See below manufacturer's Data Sheet</p>
<p>Cummins Powercommand OTEC Transfer Switch -Commercial/Industrial Grade – Frame A -UL TYPE 12 Enclosure -Voltage Rating up to 240 V -100 Amp Breaker -Automatic Transfer</p>	<p>See below manufacturer's Data Sheet</p>
<p>3KVA Buck&Boost Transformer Model T113076 -240v to 208v</p>	<p>See below manufacturer's Data Sheet</p>

ATTACHMENTS:

- A1. GENERATOR W/FUEL TANK – SPEC SHEET (BID ITEM 1)
- A2. AUTOMATIC TRANSFER SWITCH – SPEC SHEET (BID ITEM 2)
- A3. BOOST&BUCK TRANSFORMER – SPEC SHEET (BID ITEM 3)

END OF SPECIFICATIONS

CITY OF PORT ANGELES

Bid No. MEC-2024-41

BID FORM WTP SCADA GENERATOR PURCHASE

Bidder must bid on all bid items for a bid to be considered valid. The Bidder hereby bids the following amounts for all material described in the Contract Documents.

Bid Items #	Description	QTY (ea)	Unit Price	Extended Price
1	Cummins 20KW Diesel Generator With Undermount Tank Model C20 D6 Commercial/Industrial -120/240v AC Single Phase -6 Amp Battery Charger -12 Volt Starting Voltage -24 Hour Tank Capacity -pcc1.1 two-wire start control -100 amp circuit breaker -coolant heater -68.4 dba enclosure -self contained engine mounted muffler -Double Wall Diesel Tank with Leak Detection	1		
2	1x Cummins Powercommand OTEC Transfer Switch -Commercial/Industrial Grade – Frame A -UL TYPE 12 Enclosure -Voltage Rating up to 240 V -100 Amp Breaker -Automatic Transfer	1		
3	1x 3KVA Buck&Boost Transformer Model T113076 -240v to 208v	1		
			Subtotal:	
			Freight:	
			Sales Tax (8.9%):	
			Total Bid Amount:	
Delivery	Indicate estimated number of days after the purchase order is received that equipment will be delivered to the City, not to exceed 200 days.	Days: _____		