



**ADDENDUM NO. 1
TO
PROJECT MANUAL
FOR
PUMP STATION 3 – CONTROL PANEL
EQUIPMENT PURCHASE**

PROJECT NO. MEC-2020-04

**NOTICE TO PROSPECTIVE BIDDERS
Bid Opening 2:00 PM, Wednesday, April 8th, 2020**

NOTICE IS HEREBY GIVEN that the instructions and requirements of the subject bid are amended as follows:

TABLE OF CONTENTS

RESPONSE TO QUESTIONS RECEIVED AS OF [03/26/2020]1
SPECIFICATIONS1

RESPONSE TO QUESTIONS RECEIVED AS OF [03/26/2020]

- 1) **Question:** Are VFD standards going to be included/published as part of this bid package?

Response: VFD standards are provided below.

SPECIFICATIONS

- 1) Add the following to the end of Section 17500 – Site Control Panel Package

2.15 VARIABLE FREQUENCY DRIVES

- A. Furnish Yasakawa U1000 Industrial MATRIX drives, no equal.
- B. Install drives in accordance with the manufacturer’s recommendations.

The Bid Opening date and time **HAS NOT** been changed.

This addendum must be acknowledged in the space provided on the Bid Form in the Project Manual that is submitted to the City. Failure to do so may result in the proposal being rejected as non-responsive.

Signed

A handwritten signature in black ink that reads "Jonathan Boehme".

Jonathan Boehme, PE
City Engineer