



**ADDENDUM NO. 3
TO
PROJECT MANUAL
FOR
PUMP STATION 3 – CONTROL PANEL
EQUIPMENT PURCHASE**

PROJECT NO. MEC-2020-04

**NOTICE TO PROSPECTIVE BIDDERS
Bid Opening 2:00 PM, Wednesday, April 8th, 2020**

NOTICE IS HEREBY GIVEN that the instructions and requirements of the subject bid are amended as follows:

TABLE OF CONTENTS

RESPONSE TO QUESTIONS RECEIVED AS OF [04/06/2020]	1
ATTACHMENTS:.....	2
REVISED BID FORM.....	3

RESPONSE TO QUESTIONS RECEIVED AS OF [04/06/2020]

- 1) **Question:** Do you happen to have motor nameplate/data package available?

Response: Wetwell Mounted Pump Station Prepurchase Reference Document is provided below.

- 2) **Question:** Drawing E3 shows an operator Interface in the middle section of the panel. There is no specification for this. Please send make and model number of the desired Operator Interface.

Response: Desired operator interface product information is provided below

- 3) **Question:** Please confirm the programming for the PLC/OIT is required. Also is SCADA programming required on this?

Response: Programming for the PLC/OIT is required. SCADA programming using the City's WinCC software package is required.

- 4) **Question:** It seems the spare parts list per bid item 2 isn't defined. Please identify which parts are needed as spares

Response: Remove Bid Item 2 – Spare Parts. Spare parts will be procured by the City. See revised Bid Form page 3.

- 5) **Question:** Is the 80 miles stated in Supplier Minimum Qualifications Questionnaire measured as air miles or travel (roadway) miles?

Response: The mileage stated in the Supplier Minimum Qualifications Questionnaire is roadway miles.

ATTACHMENTS:

- 1) Add the following to the Attachments Section.

Attachment 2: Wetwell Mounted Pump Station Prepurchase Reference Document

Attachment 3: HMI Product Information

The Bid Opening date and time **HAS NOT** been changed.

This addendum must be acknowledged in the space provided on the Bid Form in the Project Manual that is submitted to the City. Failure to do so may result in the proposal being rejected as non-responsive.

Signed



Jonathan Boehme, PE
City Engineer

CITY OF PORT ANGELES

Bid No. MEC-2019-51

BID FORM PUMP STATION 3 – CONTROL PANEL EQUIPMENT PURCHASE

Bidder must bid on all bid items for a bid to be considered valid. The Bidder hereby bids the following amounts for all material described in the Contract Documents.

Bid Items #	Description Pump Station 3 – Control Panel Equipment	QTY (ea)	Unit Price	Extended Price
1	Control Panel	1		
3	Field Service, Start-up and Training Site Visit	1		
			Subtotal:	
			Freight	
			Sales Tax (8.8%)	
			Total Bid Amount:	

Delivery	Indicate estimated number of days after the purchase order is received that initial delivery will be shipped to the City.	Days: _____
-----------------	---	-------------